FOR MYSORE STATE

PUBLIC WORKS (195 4) Department.

MS. SERIES.

Passed
1
7 Apl

G.O. No. 1587

Dated 3rd May 1954.

[Despatch Abstract.]

Buildings - Coimbatore District - Government Hospital, Kollegal - Replacement of three 50 cycle fans by three 25 cycle fans - Estimate Rs.700/- -- Approved.

Medical Department.

From

DR.M.V.Ramanmurti, M.B.B.S, FRCS(Edin),
Director of Medical Services, Madras.6.

To

The Secretary to Government, Health Department,
Madras.

37672

Ref.no. 46176/W/53 dated 10-7-53.

Sir,

Sub: Buildings- Coimbatore District - Government Hospital, Kollegal - replacing the 50 cycle fans by 25 cycle new ceiling fans.

I am to forward herewith an estimate amounting Rs. 1050/- for replacing the 50 cycle fans by 25 cycle new ceiling fans in the Government Hospital, Kollegal for the administrative approval of the Government. The necessity for the above work has been explained in the report accompanying the estimate.

Yours faithfully,

Raghavachari

for Director of Medical Services.

krr.10.7.

Health (Hq)

Conf 37672/53

14/11/8

Subject: Buildings - Coimbatore Dt - Govt Hospital, Kollegal - Replacing the 50 cycle fans by 25 cycle new ceiling fans.

Ref: From the DMS, no 46176 W/53 dt 10.7.53

MEMO: no 37672 H/53-2 Health dt 10.8.53

The DMS is informed that it is seen from the report accompanying the estimate forwarded with his letter cited that the existing 50 cycle fans were allowed in the Govt Hospital at Kollegal in 1942, that the supply at 50 cycles was changed to 25 cycles in 1948 and that the fans are therefore not functioning from 1948.

delay. The DTCs is therefore requested to furnish in greater detail the need to provide another 3 A.C. (25T) cycle fans after a lapse of about 15 years ~~is not clear. He is, therefore, requested to furnish detailed information as to~~ and to state how 3 (25) cycle fans, proposed to be installed, ~~in the canteen~~ will be used in the Govt Hospital, Kollegal.

6.8.53 SJR 6.8.53

AV 7853

SVEK 10 8 53

6 10

Dte Dms.

Clean copy for file.

Government of Madras.
Health Department.
Memorandum No. 57672-H/55-2-Health, dated the 10th August 1955.

9

Buildings - Coimbatore District - Government Hospital, Kollegal - Replacing the 50 cycle fans by 25 cycle new ceiling fans.
From the Director of Medical Services, No. 46178-H/53, dated 10th July 1955.

The Director of Medical Services is informed that it is from the report accompanying the estimate forwarded with his letter cited that the existing 50 cycle fans were allowed in the Government Hospital at Kollegal in 1942, that the supply at 50 cycles was changed to 25 cycles in 1948 and that the fans are therefore not functioning from 1948. The Director of Medical Services is therefore requested to justify in greater detail the need to provide now 3 A.C. (25) cycle fans after a lapse of about 5 years and to state how 3 (25) cycle fans, proposed to be installed, will be used in the Government Hospital, Kollegal.

S.R. Kaimar,
Secretary to Government.

To the Director of Medical Services.
1.

Forwarded/by Order.

Superintendent.

ASR.

MEDICAL DEPARTMENT.

***

From

Dr.M.V. Ramanamurti, MBBS.,FRCS.(Edin).,
Director of Medical Services, Madras-6.

To

The Secretary to Government, Health Department,
M a d r a s.

Ref.No.46176-W/53 dated 16-9-1953.

50848

ASSISTANT SECRETARY 17 SEP 1953 HEALTH DEPARTMENT

Sub:- Buildings - Coimbatore District - Government Hospital, Kollegal - Replacing the 50 cycle fan by 25 cycle new ceilig fans.

Ref:- Government Memo.No.37672.H-53-2 Health dated 10-8-1953.

The District Medical Officer, Coimbatore has been referred to in the matter. He is being reminded and a reply to the Government Memo. cited will be sent on hearing from him.

Yours faithfully,

for Director of Medical Services.

Health (Hz)
MR on 15.10.53, if necessary.
1.9.53.
2298
23/9/53
PN.15.9

Health (Hs)

Memo. No. 376.72 H/53-3 Health dated 21-X-53

51/21/10

Sub: Buildings - Coimbatore Dt. - Govt Hospital Kollegal - Replacing the 50 cycle fan by 25 cycle new ceiling fan.

Ref: From the DMS, No. 46176 W/53 dated 16.9.53.

20814

pl note

The DMS is requested to expedite the submission of his final reply in the matter.

20.10.53 KMS 20.10.53

VR 21-10-53

for D.M.S.

From

Medical Department

Lt.Col.Sangham Lal, MBBS., FRCS., DOMS.,
Director of Medical Services, Madras-6.

To

The Secretary to Government, Health Department, Madras

Ref.No.46176 D/53, dated 2-11-53.

Sir,

5 NOV 1953

Sub: Buildings - Coimbatore District - Government Hospital, Kollegal - replacing the 50 cycles fan by 25 cycles new fans.

Ref: Government Memo No.37672 H/53-2 Health dated 10-8-1953 and reminder thereon d/21-10-53

I enclose herewith a copy of letter No.3433 M dated 20-10-53 which furnishes the fnformation required by the Government.

2. There are only 3 fans fixed in the Government Hospital, Kollegal, two to the consulting rooms (male and female) and the third in the operation theatre. The three fans now proposed are to be fixed in the same places.

Yours faithfully,

for Director of Medical Services

ASE 3.11.

Copy of letter No.3433 M dated 20-10-53 from the Executive Engineer, Salem Division, Mettur Dam.

--

Ref: Your No.R.1803 C.1-53, dated 22-8-53.

--

The lapse of six years is mainly due to the difficulty in getting 25 cycle fans. In 1952, the Sericultural Expert, Kollegal requested the Public Works Department to provide 3 ceiling fans and one table fan for his office. An enquiry was made of many dealers if they can supply these fans. Only one company Messrs. Gorden Woodroff and Company quoted for the ceiling fans 25 cycles. All the rest stated that 25 cycles fans were not available with them. Even Gorden Woodroff and Company said that 25 cycles table fan was not available with them. So only 3 ceiling fans were got and fixed for the sericultural expert's office. When the Assistant District Medical Officer, Kollegal came to know that at least ceiling fans of 25 cycles were available in the market he requested the Public Works Department to provide 25 cycles fan for his hospital in place of 3 Nos. 50 cycles fans. Hence the present estimate was prepared and sent to the Medical Department for obtaining Government approval.

The three fans are proposed to be used in the same places where originally the three 50 cycle fans were functioning. The estimate may, therefore be please got sanctioned.

/True copy

for Director of Medical Services

102
14-12

12/12/53

HECA (HST) /5

Buildings – Govt. Hospital
Hospital – Jams.
From the D.M.S. No: 461764/53 dt 10.12.53

Memo. No: 37692 HST/53-5 Dated dt 12.12.53

Do the report ~~from~~ accom-anying the estimate forwarded with the letter cited it is stated that a grant of Rs. 350/- for the existing Jams is provided for in the estimate but no such provision has been made in the estimate. The DMS is requested to send a report to Govt. on the above point.

11/12/53

14/12/53

12/12/53

Dy. E. [illegible] 21/12/53

To
The DMS (with estimate returned for resubmission)
Reminded on 18.2.54.

Medical Department.

From

Lt. Col. Sangham Lal, MBBS.,FRCS.,DOMS.,
Director of Medical Services, Madras 6.

To

The Secretary to Government,
Health, Education and Local Administration Department, Madras.



M.No. 46176-M/W/53, dated February 1954.

Sub:-Government hospital, Kollegal - Provision of fan -

Ref:-Government reminder dated 18th February 1954.

The matter is under correspondence with the Executive Engineer, Salem Division, Mettur Dam. A reply will be sent to Government as soon as his report is received.

Yours faithfully,

for Director of Medical Services.

From

Medical Department

Lt.Col.Sangham Lal, MBBS.,FRCS.,DOMS.,
Director of Medical Services,Madras 6.

To

The Secretary to Government, Health Education and
Local Administration Department,Madras.

ASSISTANT SECRETARY TO GOVERNMENT
16 MAR 1954
HEALTH, EDUCATION & LOCAL

Sir, 24806

Ref.No.46176-M-53.,dated 9-3-1954.

Sub:-Buildings - Government Hospital,Kollegal - fans -

Ref:-Govt.Memo.No.37672-H-II/53-5,dated 12-12-1953.

I forward herewith revised estimate for Rs.700/- making provision for the credit for old fans in the Govt. Hospital,Kollegal for necessary sanction of Government.

Yours faithfully,

for Director of Medical Services.

Mk.8/3

P.W.(C.)

D.S

49/3/5

1901

Sub:- Buildings - Coimbatore Dist - Govt. Hospital Kollegal - Replacement of three 5-0 cycle fans by three 25 cycle fans - Estimate Rs 700/- Approved.

Ref:- From the D.M.S. No 46176-M-5-3) 9.2.54

G.O. Ms. 1587 dated 3-5-54

The Govt. approve an expenditure of Rs 700/- (Rupees seven hundred only) on account of the replacement of the three 5-0 cycle fans in the Govt. Hospital, Kollegal, Coimbatore Dist., by three 25-cycle fans.

2. The expenditure is debitable to "5-0. a. Civil works - original works - Rly - L. Medical - Minor works". The execution of this work is subject to the condition that the monetary limit fixed for minor works under the above head for 1954-55 is not exceeded.

By Order

≥ The estimates received from the DMS are forwarded to the CE

14.4.84

12/4/84

14/4/84

23.1.84 8h 4+2 6/5/84

To The CEPLD (GL)
(with attachment-4s 5-6
& 21-22 CE)
The DMS.
The AS. Hqrs Fin
Telephonic copy to Shri A. Balakrishnan, AS. Nairobi
Copy to HELA
ISC

Health (Hy)

CRO 37672/53

Sub: Buildings – Coimbatore Dt – Govt Hospital Kollegal – Provision of 25 cycle new ceiling fans

Ref: From the D.M.S. no 46176 W/53 dt 10-7-53

The ~~proposal~~ estimate submitted by the D.M.S. for replacing the 50 cycle fans by 25 cycle new ceiling fans in the Govt Hospital, Kollegal, at an estimated cost of Rs 1050/- may be approved and the ban on the provision of fans in the Govt residential and non-residential buildings relaxed. The necessity for ~~and the urgency of~~ the proposal is explained in detail in the report accompanying the estimate on p 3 cf.

P.Ward Fin may see for remarks.

JR 17.7.53 kws 17.7.53

AV 18.7.53

SKS 20/7/53 RWD/Fin

P.W.D (C.I)

The proposal at 'x' above may be agreed to in this Deptt subject to orders being taken in circulation including those of M.(P.W). The file may be passed on to Finance.

21/7/53

21/7/53

Health no. CRO 37672 H/53-1
20.7.53
28051
512

SPECIAL DEPUTY SECRETARY TO GOVERNMENT
21 JUL 1953
PUBLIC WORKS DEPARTMENT

The existing 50 cycle fans were allowed in the Govt. Hospital at Kollegal in 1942. Supply at 50 cycles was changed to 25 cycles in 1948. The fans are therefore not functioning from 1948. The need to provide now 3 A.C. 25 cycle

fans after a lapse of about 5 years is not clear. Since 1942, Govt. have also issued orders restricting the use of fans to essential cases. In the circumstances, it is advisable to obtain detailed information from the D.M.S. as to how 3 (25) cycle fans proposed to be installed will be used in the Govt. Hospital, Kollegal.

P.W.D.No. 66512/53-1
23.7.53

N
22.7.53

Fin.

ADDITIONAL DEPUTY SECRETARY TO GOVERNMENT
60252
23 JUL 1953
FINANCE DEPARTMENT

Finance (Exps)

The notes on p.p. 1-2 above may be perused. The case may be returned to Health with reference to the remarks of P.W. on p. 1-2 above.

KM 28-7-53 var 28753

31/7/53

Health

Fin. Dis. 60254/E.C./53-1
31.7.53

Health (H2)

ASSISTANT SECRETARY
12085
3 AUG 1953
HEALTH DEPARTMENT

Please see the notes of P.W. and Fin on pp 1-2 above. With reference to the remarks of P.W. at 'N' above, a draft Ord is submitted below for approval.

6.8.53 SM 7.8.53

AV 7853

SVRK 10.8.53.

Delay in receiving my table notes explanation
SVRK 10/8/53

[Issued as Memo. No. 37672/53-2H dt 10-8-53]

From the D.M.S. No: 66176/53 dt 2-11-53
The information required by the P.W. dept can be found in the letter on p. 13 c.
This may be sent to

H✓

P.W. & Finance depts for acceptance
of the proposal at ✱ ante

11/11/53. WE FM/11/53 PW/Fin

HELA dept No.
W.37672 HII
12-11-53

Pro. note of PW will be found at H1-2 ante

Further note of Finance and H.E.& L.A. Deptts and the letter of the Director of Medical Services and the EE's letter enclosed thereto may be perused. In the circumstances stated at 'A' and 'B' on p.13 CF the proposal may be agreed to in this deptt subject to orders being taken in circulation including those of M(W).

With these remarks the case may be passed on to Fin.

21.11.53. Fin

P.W.D.
97912 C/53-V
21.11.53

19.4.54 S/c a CL

Finance (Exp.B).

(Pre.Finance note on p.2 above.)

In the circumstances stated on p.13 c.f., this department may agree to the installation of three 25 cycle ceiling fans in the Govt.Hospital Kollegal, at an estimated cost of Rs 1,050, subject to the following remarks:- // In the report accompanying the estimate, it is stated that a sum of Rs 350 for the existing fans is provided for in the estimate. But No such provision has, however, been made in the estimate - please see p.5 c.f. HELA may be requested to obtain a report on this point before according sanction to the work.

8/12/53 HELA

Rec. on 27 IX from in CB.

Fin. dis. 88602/Exp.B.53.

6.12.53

HELA (VII)

With ref: to the note of Finance dept. on p 3 ante a Draft Memo. to the D.M.S. is submitted below for approval.

11/12/53

(Memo. No. 37672 VII/53-9 12.12.53)

From the D.M.S. No. 46136M/53 of 8.3.54.

The D.M.S. has now forwarded a revised estimate for Rs. 700/- for the provision of fans in the Govt. Hospital, Kollegal. Necessary sanction may be accorded for the expenditure of Rs. 700/- for providing fans in the hospital.

May be sent to P.W. dept. and Finance dept. for remarks.

11/3/54

P.W./Fin

11/3/54

P.W.(C.)

(Re. note of P.W. at p 3 ante)

Subsequent note of Finance and HELA may be perused. The revised estimate after giving credit for the old 3 fans (50 cycles) amounts to Rs 700/- only. This may be agreed to in this deptt. However as the estimate exceeds Rs 500/- HELA may be requested to obtain orders in circulation including those of the Minister Concerned and M(F+E).

P.W. UO 20640

12/3/54

16.3.54

16/3/54

ADDITIONAL DEPUTY SECRETARY TO GOVERNMENT
16 MAR 1954
FINANCE DEPARTMENT

HELA dept No. M. 37672 VII/53
11.3.54.

DEPUTY ASST. SECRETARY
12 MAR 1954
PUBLIC WORKS DEPARTMENT

20640

3767

Fin (Ests) dept

[Pencil: Preceding finance note on p 3 above]

C.W. The proposal to replace the three 50 cycle fans by three 25 cycle fans in the Govt Hospital, Kollegal at an estimated cost of Rs 700/- may be agreed to in finance. This dept. need not call for circulation to H (PHE).

22/3/54 · 23.3.54

26/3/54

Fin #30404 EB/54
24.3.54

HELA

Note for circulation. HELA (HH) dept

In the Govt. Hospital, Kollegal, there are three 50 cycle fans. Since the electric supply at Kollegal has been changed in 1948 from 50 cycles to 25 cycles, the fans are not working. It is now proposed to replace the three 50 cycle fans by three 25 cycle fans at a cost of Rs. 700/- It is proposed to sanction the replacement of the fans. P.W. dept and Finance dept have agreed to the proposal.

~~May be sanctioned~~ submitted to M(H) & M(W) for approval.

26/3/54.

27-3-54

26/3/54

S.A. Sulekan
29.3.54

M(H) 30/3

M(W) 31/3

M(PHE) 3.4.54

P.S.T.S.
ASSISTANT SECRETARY TO GOVERNMENT
25 MAR 1954
HEALTH, EDUCATION & LOCAL ADMN. DEPT.

30853 P

6 APR 1954
HEALTH, EDN. & LOCAL ADMN.

6

HERA (HVI)

May be sent to P.W. dept. for the issue orders

29417.

HERA dept No. W. 37652 HVII 7-4-54.

DDL. ASST. SECRETARY TO GOVERNMENT 8-APR 1954 PUBLIC [illegible]

with reference to orders in circulation at P.S. ante, a draft order is submitted for approval.

Finance may see before issue

14.4.54 Fin

Fin (EB) Deptt.

Pin vo 2941 Comms 14.4.54

[Receive finance note on P.S. above]

The orders in circulation on P.S. above and the Draft order below may be issued.

23/4/54 15.4.54

DEPUTY SECRETARY TO GOVERNMENT 15 APR 1954 39039 FINANCE DEPARTMENT

HERA HVII

Fin. U.O. 39039 EB/54-1 27-4-54

Misc. P.W. dept No.

35389

28/4/54.

ASSISTANT SECRETARY TO GOVERNMENT 28 APL 1954 HEALTH, EDUCATION & LOCAL ADMN. DEPT.

P.W. (E,I)

The draft order below may now issue.

1.5.54

HERA dept No. 43434 HVII 30 APR 1954

30/4/54 [Issued as GOMS 157 PWD 3.5.54]